



Translation

EC-Type Examination Certificate

(1)

(2)

**- Directive 94/9/EC -
Equipment and protective systems intended for use
in potentially explosive atmospheres**

(3)

BVS 05 ATEX E 111 U

(4)

Equipment: Signal Processing Device type 800

(5)

Manufacturer: Micro Motion, Inc.

(6)

Address: Boulder, Co. 80301, USA

(7)

The design and construction of this component and any acceptable variation thereto are specified in the schedule to this type examination certificate.

(8)

The certification body of EXAM BBG Prüf- und Zertifizier GmbH, notified body no. 0158 in accordance with Article 9 of the Directive 94/9/EC of the European Parliament and the Council of 23 March 1994, certifies that this component has been found to comply with the Essential Health and Safety Requirements relating to the design and construction of equipment and protective systems intended for use in potentially explosive atmospheres, given in Annex II to the Directive.

The examination and test results are recorded in the test and assessment report BVS PP 05.2075 EG.

(9)

The Essential Health and Safety Requirements are assured by compliance with:

EN 50014:1997+A1-A2 General requirements

EN 50020:2002 Intrinsic safety 'i'

(10)

The sign "U" placed after the certificate number indicates that the certificate must not be mistaken for a certificate for equipment or a protective system. This certificate may only be used as the basis for the certification of equipment or a protective system.

(11)

This EC-Type Examination Certificate relates only to the design, examination and tests of the specified component in accordance to Directive 94/9/EC.

Further requirements of the Directive apply to the manufacturing process and supply of this component. These are not covered by this certificate.

(12)

The marking of the equipment shall include the following:



II 2G EEx ib IIB/IIC T5

EXAM BBG Prüf- und Zertifizier GmbH

Bochum, dated 21. July 2005

Signed: Migenda

Signed: Dr. Eickhoff

Certification body

Special services unit

(13) Appendix to

(14) **EC-Type Examination Certificate**

BVS 05 ATEX E 111 U

(15) 15.1 Subject and type
 Signal Processing Device type 800

15.2 Description

The signal processing device is used for the connection of sensors to transmitters.

The electrical components are completely encapsulated in a plastic housing. On the top of the housing are terminals for the connection of the circuits from/to the transmitter and the connection of the sensor is by means of a permanently connected cable with a 9 pin connector.

15.3 Parameters

15.3.1 Input circuit (terminals J1-1, J1-2, J2-1 and J2-2)

Voltage	U _i	DC	17,3	V
Current	I _i		484	mA
Power	P _i		2,1	W
Effective internal capacitance	C _i		2200	pF
Effective internal inductance	L _i		30	μH

15.3.2 Output (sensor) circuits

15.3.2.1 Drive circuit (J4 pins 7 - 8)

Voltage	U _o	DC	10,5	V
Current	I _o		2,45	A
Power	P _o		2,54	W
Internal resistance	R _i		4,32	Ω

for group IIC

max. external capacitance	C _o		2,41	μF
max. external inductance	L _o		5,9	μH
max. external inductance/resistance ratio	L _o /R _o		5,5	μH/Ω

for group IIB

max. external capacitance	C _o		16,8	μF
max. external inductance	L _o		24	μH
max. external inductance/resistance ratio	L _o /R _o		22	μH/Ω

15.3.2.2 Pick-Off circuits (J4 pins 3up to 6)

Voltage	U _o	DC	17,3	V
Current	I _o		18,05	mA
Power	P _o		30	mW

for group IIC				
max. external capacitance	Co		353	nF
max. external inductance	Lo		109	mH
max. external inductance/resistance ratio	Lo/Ro		1,19	mH/Ω

for group IIB				
max. external capacitance	Co		2,06	μF
max. external inductance	Lo		436	mH
max. external inductance/resistance ratio	Lo/Ro		4,75	mH/Ω

15.3.2.3 Temperature sensor circuit (J4 pins 1, 2 and 9)

Voltage	Uo	DC	17,3	V
Current	Io		4,61	mA
Power	Po		20	mW

for group IIC				
max. external capacitance	Co		353	nF
max. external inductance	Lo		1,67	H
max. external inductance/resistance ratio	Lo/Ro		1,78	mH/Ω

for group IIB				
max. external capacitance	Co		2,06	μF
max. external inductance	Lo		6,69	H
max. external inductance/resistance ratio	Lo/Ro		7,14	mH/Ω

15.3.3 Ambient temperature range Ta -40 °C up to +60 °C

(16) Test and assessment report
BVS PP 05.2075 EG as of 21.07.2005

(17) Special conditions for safe use

- 17.1 The signal processing device has to be mounted inside an enclosure with a min. degree of protection of IP 20 in accordance with EN 60529.
- 17.2 The installation of the signal processing device inside an enclosure has to be done in a way that the clearances between the connection facilities and earthed metal parts is min. 3 mm.

We confirm the correctness of the translation from the German original.
In the case of arbitration only the German wording shall be valid and binding.

44809 Bochum, 21.07 2005
BVS-Schu/Mi A 20050328

EXAM BBG Prüf- und Zertifizier GmbH



Certification body



Special services unit

EXAM · Postfach 10 27 48 · 44727 Bochum

Carl-Beyling-Haus
Dinnendahlstrasse 9
44809 Bochum

Telefon 0234 – 3696-105
Telefax 0234 – 3696-110

Micro Motion, Inc.
7070 Winchester Circle
Boulder, Co.
USA

Ihr Zeichen	H. van Holland
Ihre Nachricht	14.09.2005
Unser Zeichen	A 20050542 BVS-Schu/Mi
Durchwahl	Tel.: (0234) 3696 105 Fax: (0234) 3696 110
e-mail	Schumann@bg-exam.de
Datum	10.10.2005

Ladies and Gentlemen,

we added the Revision Report as of 10.10.2005 to the Test and Assessment Report
BVS PP 05.2075 EG.

We confirm, that the Certificate

BVS 05 ATEX E 111 U as of 21.07.2005

is still valid.

Kind regards
BBG Prüf- und Zertifizier GmbH

H. van Holland

H. van Holland

Enclosures: Revision Report
Descriptive Documents
Invoice

EXAM
BBG Prüf- und Zertifizier
GmbH

Geschäftsführung:
Dr.-Ing. Reinhard Bassier
Dr.-Ing. Günter Levin

Sitz: Bochum
Amtsgericht Bochum
HRB 5357

Bankverbindung:
Commerzbank Bochum
BLZ 430 400 36
Konto 20 50 250

e-mail: info@bg-exam.de
<http://www.bg-exam.de>

EXAM - Postfach 10 27 48 · 44727 Bochum

Micro Motion, Inc.
7070 Winchester Circle
Boulder, Co.
USA

Carl-Beyling-Haus
Dinnendahlstrasse 9
44809 Bochum

Telefon 0234 – 3696-105
Telefax 0234 – 3696-110

Ihr Zeichen H. van Holland
Ihre Nachricht 24.01.2006
Unser Zeichen A 20060066 BVS-Schu/Mi
Durchwahl Tel.: (0234) 3696 105 Fax: (0234) 3696 110
e-mail Schumann@bg-exam.de
Datum 02.02.2006

Ladies and Gentlemen,

we added the Revision Report as of 02.02.2006 to the Test and Assessment Report
BVS PP 05.2075 EG.

We confirm, that the Certificate

BVS 05 ATEX E 111 U as of 21.07.2005

is still valid.

Kind regards
BBG Prüf- und Zertifizier GmbH


(Dr. Jockers)


(Dr. Eickhoff)

Enclosures: Revision Report
Descriptive Documents
Invoice

EXAM
BBG Prüf- und Zertifizier
GmbH

Geschäftsführung:
Dr.-Ing. Reinhard Bassier
Dr.-Ing. Günter Levin

Sitz: Bochum
Amtsgericht Bochum
HRB 5357

Bankverbindung:
Commerzbank Bochum
BLZ 430 400 36
Konto 20 50 250

e-mail: info@bg-exam.de
<http://www.bg-exam.de>



Translation

1st Supplement

(Supplement in accordance with Directive 94/9/EC Annex III number 6)

to the EC-Type Examination Certificate BVS 05 ATEX E 111 U

Equipment: Signal Processing Device type 800
Manufacturer: Micro Motion, Inc.
Address: Boulder, Co. 80301, USA

Description

The unit can be modified according to the descriptive documents as mentioned in the pertinent test and assessment report. Also for testing of the unit the standards EN 60079-* have been taken as basis; a modified marking is the result.

The Essential Health and Safety Requirements of the modified equipment are assured by compliance with:
EN 60079-0:2006 General requirements
EN 60079-11:2007 Intrinsic safety 'i'

The marking of the equipment shall include the following:

 **II 2G Ex ib IIB/IIC T5**

Special conditions for safe use

Not Changed

Test and assessment report

BVS PP 05.2075 EG as of 03.08.2007

DEKRA EXAM GmbH

Bochum, dated 03. August 2007

Signed: Dr. Jockers

Signed: Dr. Eickhoff


Certification body

Special services unit


We confirm the correctness of the translation from the German original.
In the case of arbitration only the German wording shall be valid and binding.

44809 Bochum, 03.08.2007
BVS-Schu/Mi A 20070234

DEKRA EXAM GmbH



Certification body



Special services unit

DEKRA EXAM GmbH · Postfach 10 27 48 · 44727 Bochum

Emerson Process Management Flow BV
Attn. Mr. Henk van Holland
Neonstraat 1
6718 WX Ede
THE NEDERLANDS

DEKRA EXAM GmbH
Fachstelle für Sicherheit
elektrischer Betriebsmittel - BVS
Dinnendahlstraße 9
44809 Bochum
Telefon +49.234.3696-300
Telefax +49.234.3696-301

Kontakt
Tel. direkt +49.234.3696-358
Fax direkt +49.234.3696-301
E-Mail guenther.schumann@dekra.com
Datum 03.08.2010
Unser Zeichen: BVS-Schu/Tro 20100605
Ihr Zeichen: BVS 05 AEX E 111 U and
IECEX BVS 05.0010 U
Ihre Nachricht: 01.06.2010

Signal Processing Device type 800 (BVS 05 ATEX E 111 U)

Dear Sir or Madame,

We added the Revision Report as of 3rd August 2010 to the Test and Assessment Report BVS PP 05.2075 EG.

We confirm, that the Certificate

BVS 05 ATEX E 111 U as of 21st July.2005, last modification as of 3rd August 2007. is still valid.

Yours sincerely
DEKRA EXAM GmbH



Enclosures